



Town of Groveland
Water and Sewer Department
183 Main Street
Groveland, MA 01834
978-372-4144 Fax 978-373-6147

5/13/2014

Installation of Deduct Meter

Recommended Backflow Devices

Description:

Body: Bronze
Discs: Silicone
Pressure: 175 PSI

Springs: Stainless Steel
Temp: 140° F (60° C)

Model PVB Anti-Siphon Pressure Vacuum Breakers prevent backflow of pollutants or contaminated water into the potable water system due to backsiphonage. It consists of bronze body with a silicone rubber check valve disc, stainless steel springs, a ABS corrosion resistant access cover and tee handles or lever handle shutoffs. Model PVB are used in health hazard continuous pressure applications such as irrigation systems in only backsiphonage conditions. *Must be installed 12" above highest outlet in system.*

Be Advised, The Town of Groveland has a Containment Cross Connection Control Policy for All New Services. The installation of a Deduct Meter requires the main service line to be protected with a Dual Check Valve, refer to New Service Requirements.

Typical Installation

